

## Microgeneration Checklist Report

calculated by program SAP Calculator version 3.3, printed on 13, October 2009, at 14:39:45

SAP assessment by Site Measurement Services Ltd

, St Marys Lane, , postal code RM13 3QA

Applicable regulations: England and Wales

The results of the calculation should not be accepted without first checking the input data

### Example Heat Pump Project

#### HEAT PUMP

---

##### 1. Comparison in Dwelling Emission Rate (DER)

Dwelling existing heating system DER = 42.43 kg/m<sup>2</sup>

Dwelling with microgeneration included DER = 31.32 kg/m<sup>2</sup>

Projected reduction in carbon emissions 35.47%

---

##### 2. Fabric U-values

U-values:	<u>Element</u>	<u>Average</u>	<u>Highest</u>
	Wall	0.30 (max. 0.35)	0.30 (max. 0.70)
	Floor	0.84 (max. 0.25)	0.84 (max. 0.70)
	Roof	0.40 (max. 0.25)	0.40 (max. 0.35)
	Openings	1.96 (max. 2.20)	3.90 (max. 3.30)

---

##### 2.1 Heating efficiency

Main heating system: Central Heating systems (wet), Heat pump, Ground-to-water heat pump with auxiliary heater (electric) (Table 4a)

Efficiency: 300.0 %

Minimum: 300.0 %

Secondary heating system: Room heater systems, Electric (direct-acting), Panel, convector or radiant heaters

Efficiency: 100.00

Minimum: 100.00

---

##### 2.2 Cylinder insulation

Hot water storage      Nominal cylinder loss:      1.67 kWh/day  
                                 Permitted by DHCG      2.10

Primary pipework insulated:      No

---

##### 2.3 Controls

Space heating controls      Programmer + at least two room thermostats

Hot water controls:

    Cylinderstat

    Cylinder timer

---

## 2.4 Microgeneration system details - heat pump

### Heat pump input data:

Heating system	Central Heating systems (wet)
Fuel	Electricity 7-hour
Heat Source	Heat pump
Heating Controls	Programmer + at least two room thermostats
System	Ground-to-water heat pump with auxiliary
heater (electric)	
Heat emitters	Radiators
Boiler efficiency (default)	300.00%
Pump in heated space Or Warm Air Fan	No
Condensing Boiler has load or weather	No
Fan Assisted	No
Boiler Interlock	No
Boiler in heated space	No
Delayed start	No

The performance of Microgeneration heat pump systems is impossible to predict with certainty due to the variability of the climate and its subsequent effect on both heat supply and demand. This estimate is based upon the best available information but is given as guidance only and should not be considered as a guarantee.

---